



Certificate / Certificat Zertifikat / 合格証

LAD 2007099 C001

exida hereby confirms that the:

Floating Ball Valves

**Ladish Valves
Houston, TX USA**

The manufacturer
may use the mark:



Revision 1.0 January 12, 2022
Surveillance Audit Due
February 1, 2025

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

LAD 2007099 C001

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Systematic Capability :

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

Versions:

PF Floating Ball Valve Series: 401, 411, 421, 451

S Floating Ball Valve Series: S

IEC 61508 Failure Rates in FIT¹ Static Applications

Application/Device/Configuration	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke, Clean Service	0	0	0	425
Tight Shut-Off, Clean Service	0	0	0	1176
Open on Trip, Clean Service	0	121	0	304
Full Stroke, Severe Service	0	0	0	750
Tight Shut-Off, Severe Service	0	0	0	2236
Open on Trip, Severe Service	0	242	0	508
Cryogenic Full Stroke, Clean Service	0	0	0	457
Cryogenic Tight Shut-Off, Clean Service	0	0	0	1193
Cryogenic Open on Trip, Clean Service	0	121	0	337
Cryogenic Full Stroke, Severe Service	0	0	0	780
Cryogenic Tight Shut-Off, Severe Service	0	0	0	2252
Cryogenic Open on Trip, Severe Service	0	242	0	538

¹FIT – 1 failure/10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: LAD 2007099 R002 V1R1 (or later)

Safety Manual: Ladish Ball Valve Safety Manual Rev A (or later)

Floating Ball Valves



80 N Main St
Sellersville, PA 18960

T-061, V5R2